



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

June 4, 2024

Attention: Madeline  
General Manager

Subject: May 2024 Monthly Report

On the billing cycle ending on the 21<sup>ST</sup> of May 28,843,000 gallons of water were used by our consumers, an average of 995,000 gallons was used per day.

On May 24, 2024, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on May 30, 2024 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 59 ppb for the Mc Cabe site and 47 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

June 04, 2024

Attention: Madeline  
General Manager

Subject: Water Distribution Report May 2024

A) Water breaks (0)

B) Service Leak (2)

1. 59 Mc Cabe Road
2. 23 Mustang Road


C) Work orders ( 71 )

INFO- TEST METER	2
LEAK - METER LEAK	6
VALVE – REPLACE SHUT OFF VALVE	1
HYDRANT – HYDRANT LEAK	1
PRSUR – TEST WATER PRESSURE	1
CON - CONNECT	5
WTDRK – DIRTY/ DARK WATER	1
MC - METER CHANGE	18
OCC - OCCUPANT CHANGE	6
DIS - DISCONNECT	5
FIRF - ENCODER/FIREFLY	22
WTR - SERVICE LINE LEAK	2
PRSUR - TEST WATER PRESURE	1
TOTAL ALL CODES	71

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Water Chief Operator  
Heber Public Utility District



## Heber Public Utility District

1078 Dogwood Rd, Suite 103 • P. O. Box H  
Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

June 10, 2024

Attention: Madeline Dessert  
General Manager

SUBJECT: Heber W.W.T.P. Operations from April 22, 2024 through May 21, 2024.

- A. Major violations: (NONE)
- B. Minor violations: (NONE)
- C. Major sewer spills: (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning.
- F. Vactor Truck: Vactor truck was used on May 1, 2024 in the alley of Grand and Heber Ave to repair a water leak.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0 miles.
- H. From April 22, 2024 through May 21, 2024: Heber Wastewater Plant received and treated 14.607 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of May 21, 2024.

Sincerely,

A handwritten signature in blue ink, appearing to be "ESG".

Edoardo S. Gonzalez  
Wastewater Plant Lead Operator

*Heber Public Utility District is an equal opportunity provider and employer*




HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report  
 Billing Period : April 22, THRU May 21, 2024

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
May-23	24,937,000	27,283,599	2,091,376	-4,437,975	13,429,000	\$ 145,124.77	\$ 116,710.16	\$ 54,054.90	160 Accounts
Jun-23	28,781,000	29,925,186	2,454,108	-3,598,294	14,212,000	\$ 149,604.48	\$ 117,451.77	\$ 54,154.44	160 Accounts
Jul-23	30,540,000	33,019,108	2,481,826	-4,960,934	12,877,000	\$ 158,940.92	\$ 117,756.38	\$ 55,755.67	160 Accounts
Aug-23	31,134,000	29,923,590	2,513,664	-1,303,254	13,991,000	\$ 150,960.04	\$ 117,671.85	\$ 55,810.93	160 Accounts
Sep-23	34,405,000	27,531,530	2,616,579	4,256,891	13,723,000	\$ 143,774.19	\$ 117,357.33	\$ 55,767.32	160 Accounts
Oct-23	30,110,000	27,412,985	2,231,252	465,763	14,544,000	\$ 144,521.19	\$ 117,579.77	\$ 55,759.60	160 Accounts
Nov-23	24,697,000	23,117,991	1,764,615	-185,606	15,743,000	\$ 137,195.23	\$ 117,267.22	\$ 55,685.68	160 Accounts
Dec-23	20,976,000	21,708,288	2,543,739	-3,276,027	14,691,000	\$ 135,839.85	\$ 116,781.70	\$ 55,576.30	160 Accounts
Jan-24	20,638,366	18,135,000	1,825,771	677,595	15,560,000	\$ 134,297.40	\$ 117,302.21	\$ 55,426.19	160 Accounts
Feb-24	15,667,000	16,178,248	2,054,462	-2,565,710	17,779,000	\$ 124,392.83	\$ 116,000.69	\$ 55,382.61	160 Accounts
Mar-24	20,322,000	21,108,650	1,837,250	-2,623,900	16,197,000	\$ 129,995.46	\$ 116,490.45	\$ 56,706.82	160 Accounts
Apr-24	25,549,000	24,474,159	2,026,456	-951,615	16,037,000	\$ 137,142.31	\$ 116,538.21	\$ 57,140.44	159 Accounts
<b>May-24</b>	<b>28,843,000</b>	<b>27,127,172</b>	<b>2,558,028</b>	<b>-842,200</b>	<b>14,607,000</b>	<b>\$ 142,812.36</b>	<b>\$ 117,203.17</b>	<b>\$ 57,081.99</b>	<b>159 Accounts</b>

Totals includes billing for final accounts  
 To the best of my knowledge, the information is true and correct.

  
 Liz German  
 Office Senior Clerk

6/10/24  
 Date

## \*\*\*\* TOTALS BY JOB CODE \*\*\*\*

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
VALVE - REPLACE SHUT OF VALVE	1	0	0	0	0
MC - METER CHANGE	18	1	1	0	0
DIS - DISCONNECT	5	0	0	0	9
HYDRT - HYDRANT LEAK	2	0	0	0	0
FIREF - ENCODER/FIRELY	22	0	0	0	0
CON - CONNECT	5	0	0	0	0
PRSUR - TEST WATER PRESSURE	1	0	0	0	0
LEAK - METER LEAK	6	4	0	0	0
OCC - OCCUPANT CHANGE	6	0	0	0	0
INFO - TEST METER	2	1	0	0	0
WTR - SERVICE LINE LEAK	2	0	0	0	0
WTRK - DIRTY/DARK WATER	1	0	0	0	0
MISC - MISC REPORT	0	1	0	0	0
TOTAL ALL CODES	71	7	1	0	9