

Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

October 3, 2024

Attention: Madeline
General Manager

Subject: September 2024 Monthly Report

On the billing cycles ending on the 20TH of September 36,091,000 gallons of water were used by our consumers, an average of 1,164,000 gallons was used per day.

On September 19, 2024 collected third quarter TTHM's samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on September 27, 2024 and were below the maximum contaminant level (MCL) for the both sites. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and for the month of September of 2024 we attained a RAA of 62 ppb for the Mc Cabe Cove site and 50 ppb for the Little Field site. Heber Public Utility District is in compliance with State and Federal water regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel: (760)482-2440 • Fax (760)353-9951

October 3, 2024

Attention: Madeline
General Manager

Subject: Water Distribution Report September 2024

A) Water breaks (1)

1. 1119 Heber Ave.

B) Service Leak (1)

1. 74 10th St


C) Work orders (45)

INFO - TEST METER	8
WTR – SERVICE LINE BREAK	2
VALVE – REPLACE SHUT OFF VALVE	1
MC - METER CHANGE	5
DIS - DISCONNECT	5
CON - CONNECT	5
OCC - OCCUPANT CHANGE	4
LEAK - METER LEAK	12
HYDRT – HYDRANT LEAKS	1
<u>PRSUR – TEST WATER PRESSURE</u>	<u>2</u>
 TOTAL ALL CODES	 45

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

October 3, 2024

Attention: Madeline Dessert
General Manager

SUBJECT: Heber W.W.T.P. Operations from August 20, 2024 through September 20, 2024.

- A. Major violations: (NONE)
- B. Minor violations: (NONE)
- C. Major sewer spills: (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning.
- F. Vector Truck: Vector truck was not used this monthly cycle.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0 miles.
- H. From May 21, 2024 through June 21, 2024: Heber Wastewater Plant received and treated 14.684 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of September 20, 2024.

Sincerely,

A handwritten signature in black ink, appearing to be "E. Gonzalez".

Edoardo S. Gonzalez
Wastewater Plant Lead Operator



HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report
 Billing Period : AUGUST 20, 2024 thru SEPTEMBER 20, 2024

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Sep-23	34,405,000	27,531,530	2,616,579	4,256,891	13,723,000	\$ 143,774.19	\$ 117,357.33	\$ 55,767.32	160 Accounts
Oct-23	30,110,000	27,412,985	2,231,252	465,763	14,544,000	\$ 144,521.19	\$ 117,579.77	\$ 55,759.60	160 Accounts
Nov-23	24,697,000	23,117,991	1,764,615	-185,606	15,743,000	\$ 137,195.23	\$ 117,267.22	\$ 55,685.68	160 Accounts
Dec-23	20,976,000	21,708,288	2,543,739	-3,276,027	14,691,000	\$ 135,839.85	\$ 116,781.70	\$ 55,576.30	160 Accounts
Jan-24	20,638,366	18,135,000	1,825,771	677,595	15,560,000	\$ 134,297.40	\$ 117,302.21	\$ 55,426.19	160 Accounts
Feb-24	15,667,000	16,178,248	2,054,462	-2,565,710	17,779,000	\$ 124,392.83	\$ 116,000.69	\$ 55,382.61	160 Accounts
Mar-24	20,322,000	21,108,650	1,837,250	-2,623,900	16,197,000	\$ 129,995.46	\$ 116,490.45	\$ 56,706.82	160 Accounts
Apr-24	25,549,000	24,474,159	2,026,456	-951,615	16,037,000	\$ 137,142.31	\$ 116,538.21	\$ 57,140.44	159 Accounts
May-24	28,843,000	27,127,172	2,558,028	-842,200	14,607,000	\$ 142,812.36	\$ 117,203.17	\$ 57,081.99	159 Accounts
Jun-24	37,690,000	33,120,546	1,813,047	2,756,407	15,141,000	\$ 164,837.06	\$ 117,141.44	\$ 57,132.60	160 Accounts
Jul-24	39,157,000	35,420,583	2,896,894	839,523	14,417,000	\$ 167,879.73	\$ 117,572.65	\$ 59,335.38	160 Accounts
Aug-24	37,804,000	31,835,694	2,348,695	3,619,611	13,568,000	\$ 157,634.05	\$ 117,426.53	\$ 59,321.68	160 Accounts
Sep-24	36,091,000	32,568,946	2,391,872	1,130,182	14,684,000	\$ 158,946.99	\$ 117,782.09	\$ 59,327.03	166 Accounts

Totals includes billing for final accounts
 To the best of my knowledge, the information is true and correct.

Liz German
 Liz German
 Office Senior Clerk

10/3/24
 Date

**** TOTALS BY JOB CODE ****

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
INFO - TEST METER	8	0	0	0	0
DIS -- DISCONNECT	5	0	0	0	23
CON - CONNECT	5	0	0	0	0
PRSUR - TEST WATER PRESSURE	2	1	0	0	0
LEAK - METER LEAK	12	0	0	0	0
OCC - OCCUPANT CHANGE	4	0	0	0	0
HYDR1 - HYDRANT LEAK	1	0	0	0	0
MC - METER CHANGE	5	0	0	0	0
MISC - MISC REPORT	0	1	0	0	0
WTR - SERVICE LINE LEAK	2	0	0	0	0
VALVE - REPLACE SHUT OF VALVE	1	0	0	0	0
TOTAL ALL CODES	45	2	0	0	23