



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H
Heber CA 92249
Tel:(760)482-2440 • Fax (760)353-9951
www.heber.ca.gov

September 4, 2025

Attention: Madeline
General Manager

Subject: August 2025 Monthly Report

On the billing cycles ending on the 20th of August 37,781,000 gallons of water were used by our consumers, an average of 1,219,000 gallons was used per day.

On August 20, 2025, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on August 27, 2025 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 62 ppb for the Mc Cabe site and 52 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685


Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

September 4, 2025

Attention: Madeline
General Manager

Subject: Water Distribution Report August 2025

- A) Water breaks (1)
 - 1. Alley of 1124 Grand Ave.
- B) Service Leak (0)
- C) Work Orders (105)

<u>JOB CODE</u>	<u>TOTAL COMPLETED</u>
CON - CONNECT	8
DIS - DISCONNECT	7
LEAK - METER LEAK	23
INFO - TEST METER	3
ONCAL - ONCALL OPERATOR WAS CALLED	4
MC - METER CHANGE	2
HYDRT -HYDRANT LEAK	1
PRSUR - TEST WATER PRESSURE	3
WTR - SERVICE LINE LEAK	1
MT PR - METER CHANGING PROJECT	50
OCC - OCCUPANT CHANGE	2
TEMP - TEMP SHUT OFF FOR REPAIR	1

TOTAL ALL CODES **105**

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".


Francisco Rodriguez
Chief Operator
Heber Public Utility District



HEBER PUBLIC UTILITY DISTRICT
 Water & Wastewater Treatment Plants and Billing Report
 Billing Period : JULY 20, 2025 thru AUGUST 20, 2025

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced		10% Senior Discount
	Gallons Produced	Gallons Invoiced				Water	Sewer	
Aug-24	37,804,000	31,835,694	2,348,695	3,619,611	13,568,000	\$ 157,634.05	\$ 117,426.53	160 Accounts
Sep-24	36,091,000	32,568,946	2,391,872	1,130,182	14,684,000	\$ 158,946.99	\$ 117,782.09	166 Accounts
Oct-24	30,006,000	28,543,493	2,209,711	-747,204	17,647,000	\$ 146,026.20	\$ 117,155.53	166 Accounts
Nov-24	24,426,000	24,006,473	1,978,551	-1,559,024	14,475,000	\$ 137,174.61	\$ 116,866.31	166 Accounts
Dec-24	19,145,000	21,611,874	1,346,649	-3,813,523	13,666,000	\$ 134,472.59	\$ 116,784.19	166 Accounts
Jan-25	18,836,000	19,157,768	1,531,243	-1,853,011	12,692,000	\$ 132,753.07	\$ 116,527.28	166 Accounts
Feb-25	19,618,000	20,080,938	1,664,481	-2,127,419	13,489,000	\$ 132,926.63	\$ 116,552.04	166 Accounts
Mar-25	20,043,000	20,390,552	2,187,885	-2,535,437	12,360,000	\$ 130,169.73	\$ 116,705.53	166 Accounts
Apr-25	25,993,000	25,137,709	2,961,623	-2,106,332	13,863,000	\$ 135,876.87	\$ 116,928.52	167 Accounts
May-25	30,161,000	27,730,823	3,556,069	-1,125,892	13,766,000	\$ 140,716.70	\$ 117,062.63	170 Accounts
Jun-25	33,319,000	30,156,796	3,031,154	131,050	14,599,000	\$ 148,780.49	\$ 117,216.21	170 Accounts
Jul-25	35,710,000	30,330,332	412,788	4,966,880	14,157,000	\$ 157,505.88	\$ 117,382.10	173 Accounts
Aug-25	35,291,564	37,781,000	5,036,022	-2,489,436	14,603,000	\$ 159,459.05	\$ 118,187.81	173 Accounts

Totals includes billing for final accounts
 To the best of my knowledge, the information is true and correct.


 Liz Geyman
 Office Senior Clerk
 Date 9/15/2025

**** TOTALS BY JOB CODE ****

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
LEAK - METER LEAK	23	0	0	0	0
OCC - OCCUPANT CHANGE	2	0	0	0	0
PRSUR - TEST WATER PRESSURE	3	0	0	0	0
MC - METER CHANGE	2	0	0	0	0
DIS - DISCONNECT	7	0	0	0	0
ONCAL - ONCALL OPERATOR WAS CA	4	0	0	0	0
MT PR - METER CHANGING PROJECT	50	0	0	0	1
CON - CONNECT	8	0	0	0	0
TEMP - TEMP SHUT OF FOR REPAI	1	0	0	0	0
INFO - TEST METER	3	1	0	0	0
WTR - SERVICE LINE LEAK	1	0	0	0	0
HYDRT - HYDRANT LEAK	1	0	0	0	0
TOTAL ALL CODES	105	1	0	0	1