



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H
Heber CA 92249
Tel:(760)482-2440 • Fax (760)353-9951
www.heber.ca.gov

December 3, 2025

Attention: Madeline
General Manager

Subject: November 2025 Monthly Report

On the billing cycles ending on the 18th of November 22,739,000 gallons of water were used by our consumers, an average of 758,000 gallons was used per day.

On November 12, 2025, collected the monthly Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on November 19, 2025 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 63 ppb for the McCabe site and 54 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

December 3, 2025

Attention: Madeline
General Manager

Subject: Water Distribution Report November 2025

- d) Water breaks (0)
- e) Service Leak (2)
 - 1. Intersection on Black Hills Road and Dogwood Road (County Irrigation water service line)
 - 2. 1137 Dogwood Road (Heber Woods Apartments)
- f) Work orders (110)

OCC – OCUPANT CHANGE	4
CON - CONNECT	2
SWR- SEWER PLUG UP	1
DIS - DISCONNECT	5
WTR – SERVICE LINE LEAK	1
LEAK - METER LEAK	12
PRSUR – TEST WATER PRESSURE	3
INFO - TEST METER	4
SWR – Manhole	2
HYDRT – HYDRANT LEAK	1
SC – SERVICE CHANGE	1
TEMP – TEMP SHUT OFF FOR REPAIR	1
MT PR – METER CHANGING PROJECT	73

TOTAL ALL CODES 110

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

December 3, 2025

Erica Mendoza
State Water Resources Control Board - Division of Drinking Water
Imperial District Engineer
2375 Northside Drive, Suite 100
San Diego, CA 92108

Subject: Stage 2 DBPR

Dear Ms. Mendoza

Attached, please find the Heber PUD November 2025 Monthly Stage 2 DBPR results.

If you have any questions please e-mail or call me at the number below. Thanks

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Heber Public Utility District
Chief Operator
Cell# (760) 427-4685
E-Mail: frdriguez@heber.ca.gov

Stage 2 DDBPR Quarterly TTHM Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: Heber Public Utilities District System No.: 1310007 Year: 2025 Quarter: 4th

TTHM MCL = 0.080 mg/L or 80 ug/L

Year:	2025																2026															
	1st Qtr				2nd Qtr				3rd Qtr				4th Qtr				1st Qtr				2nd Qtr				3rd Qtr				4th Qtr			
	Jan	Feb	Mar	Qtr ave	Apr	May	Jun	Qtr ave	Jul	Aug	Sept	Qtr ave	Oct	Nov	Dec	Qtr ave	Jan	Feb	Mar	Qtr ave	Apr	May	Jun	Qtr ave	Jul	Aug	Sept	Qtr ave	Oct	Nov	Dec	Qtr ave
Sample Date (m/d):	1/29	2/11	3/19	ave	4/24	5/20	6/24	ave	7/8	8/20	9/10	ave	10/15	11/12		ave				ave				ave				ave				ave
Monitoring Location																																
(900) McCabe	54.1	58.9	68.8	60.6	93.1	56.4	74.0	74.5	56.7	58.9	59.0	58.2	69.6	46.1		57.9																
(901) Littlefield	46.6	48.1	58.4	51.0	71.2	54.6	63.9	63.2	54.1	54.3	56.0	54.8	48.5	45.8		47.2																
# of Samples Taken	2	2	2	X	2	2	2	X	2	2	2	X	2	2		X				X				X				X				X
Monitoring Location																																
(900) McCabe	X	X	X	59	X	X	X	66	X	X	X	63	X	X	X	62	X	X	X		X	X	X		X	X	X		X	X	X	
(901) Littlefield	X	X	X	45	X	X	X	54	X	X	X	56	X	X	X	53	X	X	X		X	X	X		X	X	X		X	X	X	
Maximum OEL value:				59				66				63				62				0				0				0				0
Is OEL ≤ MCL for all monitoring locations? (a)				Yes				Yes				Yes				Yes																
Monitoring Location																																
(900) McCabe	X	X	X	56	X	X	X	62	X	X	X	62	X	X	X	63	X	X	X		X	X	X		X	X	X		X	X	X	
(901) Littlefield	X	X	X	43	X	X	X	48	X	X	X	52	X	X	X	54	X	X	X		X	X	X		X	X	X		X	X	X	
Maximum LRAA value:				56				62				62				63				0				0				0				0
Meets standard for all monitoring locations (i.e., LRAA ≤ MCL)? (b)				Yes				Yes				Yes				Yes																

(a) If OEL exceeds TTHM MCL, system must conduct an operational evaluation and submit a report to DDW no later than 90 days after being notified of the analytical result that caused the OEL exceedance.

(b) If LRAA exceeds the TTHM MCL, system must conduct public notification.

(c) If any individual quarter's result will cause the LRAA to exceed the TTHM MCL, the system is out of compliance at the end of that quarter.

TTHM Inspection Summary Report

Water System: Heber Public Utility District

Water System No: 1310007

Calendar Month: November 2025

Date Prepared December 3, 2025

TTHM AND CONSTITUENTS SAMPLE AND ANALYSIS REPORT

DATE	Time collected	LOCATION (PS CODE)	TTHM LEVEL (ppb)	CHLORINE RESIDUAL (mg/L)	pH (pH)	WATER TEMP. (Celsius)	TURBIDITY (ntu)	TOTAL ORGANIC CARBON (mg/L)	3 MG AERATION TANK				NOTES
									TANK ELEVATION (ft)	MIXERS IN OPERATION (1 TO 2)	AERATORS IN OPERATION (1 TO 4)	BLOWERS IN OPERATION (1 TO 2)	
11/12/2025	11:00am	Aeration Tank # 3 (1310007-004)	41.6	1.04	8.05	23.3	0.13	N/A	23	2	1	1	Noteworthy comments by Operator
11/12/2025	4:00pm	McCabe Cove Sample (1310007-900)	46.1	0.72	8.05	27.3	0.18	N/A	N/A	N/A	N/A	N/A	
11/12/2025	3:05pm	Littlfield Sample (1310007-901)	45.8	0.73	8.05	26.1	0.18	N/A	N/A	N/A	N/A	N/A	

Comments / Problems / Issues

Name: Francisco Rodriguez

Signature:



Title: HPUD Chief Operator

12/3/2025

Clinical Laboratory of San Bernardino, Inc.

Celebrating 55 Years of Analytical Service 1967-2022



Heber Public Utility District 1078 Dogwood Road, Suite 103 Heber CA, 92249	Project: Routine Sub Project: TTHMS Project Manager: Water Quality Supervisor	Work Order: 25K1531 Received: 11/14/25 09:47 Reported: 11/19/25
--	---	---

Aerotion Tank **25K1531-01 (Water)** **Sample Date:** 11/12/25 11:00 **Sampler:** Guillermo Verdugo

Analyte	Method	Result	Units	Rep. Limit	MCL	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	-------	------------	-----	----------	----------	-------	-----------

Trihalomethanes Analyses

Bromodichloromethane	EPA 524.2	12.7	ug/L	1.0		11/17/25	11/18/25	2546239	
Bromoform	EPA 524.2	1.2	ug/L	1.0		11/17/25	11/18/25	2546239	
Chloroform (Trichloromethane)	EPA 524.2	19.2	ug/L	1.0		11/17/25	11/18/25	2546239	
Dibromochloromethane	EPA 524.2	8.5	ug/L	1.0		11/17/25	11/18/25	2546239	
Total Trihalomethanes (TTHM)	EPA 524.2	41.6	ug/L	1.0	80	11/17/25	11/18/25	2546239	
<i>Surrogate: Bromofluorobenzene</i>	EPA 524.2	<i>90 %</i>				11/17/25	11/18/25	2546239	
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	EPA 524.2	<i>89 %</i>				11/17/25	11/18/25	2546239	

Stu Styles
Client Services Manager

Clinical Laboratory of San Bernardino, Inc.

Celebrating 55 Years of Analytical Service 1967-2022



Heber Public Utility District 1078 Dogwood Road, Suite 103 Heber CA, 92249	Project: Routine Sub Project: TTHMS Project Manager: Water Quality Supervisor	Work Order: 25K1531 Received: 11/14/25 09:47 Reported: 11/19/25
--	---	---

McCabe Cove **25K1531-02 (Water)** **Sample Date:** 11/12/25 11:30 **Sampler:** Guillermo Verdugo

Analyte	Method	Result	Units	Rep. Limit	MCL	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	-------	------------	-----	----------	----------	-------	-----------

Trihalomethanes Analyses

Bromodichloromethane	EPA 524.2	13.1	ug/L	1.0		11/17/25	11/18/25	2546239	
Bromoform	EPA 524.2	1.2	ug/L	1.0		11/17/25	11/18/25	2546239	
Chloroform (Trichloromethane)	EPA 524.2	23.0	ug/L	1.0		11/17/25	11/18/25	2546239	
Dibromochloromethane	EPA 524.2	8.8	ug/L	1.0		11/17/25	11/18/25	2546239	
Total Trihalomethanes (TTHM)	EPA 524.2	46.1	ug/L	1.0	80	11/17/25	11/18/25	2546239	
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	EPA 524.2	<i>91 %</i>				<i>11/17/25</i>	<i>11/18/25</i>	<i>2546239</i>	
<i>Surrogate: Bromofluorobenzene</i>	EPA 524.2	<i>92 %</i>				<i>11/17/25</i>	<i>11/18/25</i>	<i>2546239</i>	

Stu Styles
 Client Services Manager

Clinical Laboratory of San Bernardino, Inc.
Celebrating 55 Years of Analytical Service 1967-2022



Heber Public Utility District 1078 Dogwood Road, Suite 103 Heber CA, 92249	Project: Routine Sub Project: TTHMS Project Manager: Water Quality Supervisor	Work Order: 25K1531 Received: 11/14/25 09:47 Reported: 11/19/25
--	---	---

ND Analyte NOT DETECTED at or above the MDL; Method Detection Limit.

Clinical Laboratory of San Bernardino, Inc.

Celebrating 55 Years of Analytical Service 1967-2022



Heber Public Utility District 1078 Dogwood Road, Suite 103 Heber CA, 92249	Project: Routine Sub Project: TTHMS Project Manager: Water Quality Supervisor	Work Order: 25K1531 Received: 11/14/25 09:47 Reported: 11/19/25
--	---	---

Trihalomethanes Analyses - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%Rec	%Rec Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch 2546239 Analyst: AEH

Blank (2546239-BLK1) Prepared & Analyzed: 11/17/25

Bromodichloromethane	ND	1.0	ug/L							
Bromoform	ND	1.0	ug/L							
Chloroform (Trichloromethane)	ND	1.0	ug/L							
Dibromochloromethane	ND	1.0	ug/L							
Total Trihalomethanes (TTHM)	ND	1.0	ug/L							
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	5.0		ug/L	5.0		99	70-130			
<i>Surrogate: Bromofluorobenzene</i>	5.2		ug/L	5.0		103	70-130			

LCS (2546239-BS1) Prepared & Analyzed: 11/17/25

Bromodichloromethane	9.41	1.0	ug/L	10		94	70-130			
Bromoform	8.72	1.0	ug/L	10		87	70-130			
Chloroform (Trichloromethane)	9.71	1.0	ug/L	10		97	70-130			
Dibromochloromethane	8.99	1.0	ug/L	10		90	70-130			
Total Trihalomethanes (TTHM)	36.8	1.0	ug/L	40		92	70-130			
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	5.0		ug/L	5.0		100	70-130			
<i>Surrogate: Bromofluorobenzene</i>	5.0		ug/L	5.0		101	70-130			

LCS (2546239-BS2) Prepared: 11/17/25 Analyzed: 11/18/25

Bromodichloromethane	8.33	1.0	ug/L	10		83	70-130			
Bromoform	7.32	1.0	ug/L	10		73	70-130			
Chloroform (Trichloromethane)	10.2	1.0	ug/L	10		102	70-130			
Dibromochloromethane	7.42	1.0	ug/L	10		74	70-130			
Total Trihalomethanes (TTHM)	33.3	1.0	ug/L	40		83	70-130			
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	4.9		ug/L	5.0		99	70-130			
<i>Surrogate: Bromofluorobenzene</i>	4.9		ug/L	5.0		97	70-130			

LCS (2546239-BS3) Prepared: 11/17/25 Analyzed: 11/18/25

Bromodichloromethane	8.22	1.0	ug/L	10		82	70-130			
Bromoform	7.06	1.0	ug/L	10		71	70-130			
Chloroform (Trichloromethane)	10.5	1.0	ug/L	10		105	70-130			
Dibromochloromethane	7.31	1.0	ug/L	10		73	70-130			
Total Trihalomethanes (TTHM)	33.1	1.0	ug/L	40		83	70-130			
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	4.9		ug/L	5.0		97	70-130			
<i>Surrogate: Bromofluorobenzene</i>	4.8		ug/L	5.0		97	70-130			

Clinical Laboratory of San Bernardino, Inc.

Celebrating 55 Years of Analytical Service 1967-2022



Heber Public Utility District 1078 Dogwood Road, Suite 103 Heber CA, 92249	Project: Routine Sub Project: TTHMS Project Manager: Water Quality Supervisor	Work Order: 25K1531 Received: 11/14/25 09:47 Reported: 11/19/25
--	---	---

Trihalomethanes Analyses - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%Rec	%Rec Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch 2546239 Analyst: AEH

LCS (2546239-BS4)

Prepared: 11/17/25 Analyzed: 11/18/25

Bromodichloromethane	7.78	1.0	ug/L	10		78	70-130			
Bromoform	7.20	1.0	ug/L	10		72	70-130			
Chloroform (Trichloromethane)	9.36	1.0	ug/L	10		94	70-130			
Dibromochloromethane	7.26	1.0	ug/L	10		73	70-130			
Total Trihalomethanes (TTHM)	31.6	1.0	ug/L	40		79	70-130			
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	4.9		ug/L	5.0		98	70-130			
<i>Surrogate: Bromofluorobenzene</i>	4.8		ug/L	5.0		96	70-130			

LCS (2546239-BSS)

Prepared: 11/17/25 Analyzed: 11/19/25

Bromodichloromethane	9.26	1.0	ug/L	10		93	70-130			
Bromoform	8.25	1.0	ug/L	10		83	70-130			
Chloroform (Trichloromethane)	11.1	1.0	ug/L	10		111	70-130			
Dibromochloromethane	8.65	1.0	ug/L	10		86	70-130			
Total Trihalomethanes (TTHM)	37.2	1.0	ug/L	40		93	70-130			
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	5.3		ug/L	5.0		106	70-130			
<i>Surrogate: Bromofluorobenzene</i>	5.1		ug/L	5.0		102	70-130			

Stu Styles
Client Services Manager


Clinical Lab of San Bernardino, Inc.

Chain of Custody

WO 20K1531

21881 Barton Road Grand Terrace CA 92313 909 825-7693 / 516-A N 8th St. Lompoc CA 93436 805 737-7300

Client		Destination Laboratory										Analysis Requested										Comments	Turn Around Time (TAT)
Heber Public Utility Dist		<input type="checkbox"/> Clinical Grand Terrace / ELAP 1088 <input type="checkbox"/> Clinical Lompoc / ELAP 1678 <input type="checkbox"/> Other:																					
Address: 1078 Dogwood Rd Suite 103																						TTHMS (EPA 521)	
Heber CA 92249																							
Client Contact: Frank Rodriguez																							
Phone No.: 760 427 4688 FAX No.:																							
System No.: CA 1310007																							
Project: TTHMS																							
Sampled By: Guillermo Verdugo																							
Comments: Nov. TTHMS																							
Date	Time	Sample Identification		Container ID	Matrix	Sample Type	Unpreserved	No. of Preserved Cont.										Total Containers					
								As2S903	CdH806	HNO3	HCl	NaOH	Na2SO3	ZnCH3CO4									
11-17-25	11am	AERATION Tank EFF			DW		2								2								
		CA 1310007-002-064																					
11-17-25	11:30	McCABE COVE			DW		2								2								
		CA 1310007-17ST-900																					
11-17-25	12:15	Little Field			DW		2								2								
		CA 1310007-17ST-901																					
Matrix: DW - Drinking Water GW - Ground Water SW - Surface Water W - Water WW - Wastewater SR - Stormwater Runoff S - Sludge O - Other Use for Bacteria Samples / Sample Type: 1-Routine 2-Repeat 3-Replacement 4-Special D-Distribution W-Well TAT: (10) Ten Day (5) Five Day Rush (2) Two Day Rush																							
Relinquished By (Sign)		Print Name / Company				Date / Time		Received By (Sign)				Print Name / Company											
		Guillermo Verdugo				11-13-25						Vanessa / CISB											
		Heber Public Utility				11-30am																	
						11/14 947																	
(Lab Use Only) Lompoc Lab Receipt Temp.: _____ °C Shipped Via: <input type="checkbox"/> Fed Ex <input type="checkbox"/> Golden State Overnight <input type="checkbox"/> UPS <input type="checkbox"/> OnTrac <input type="checkbox"/> USPS <input type="checkbox"/> Other _____ Condition: <input type="checkbox"/> On Wet Ice <input type="checkbox"/> On Blu Ice <input type="checkbox"/> Intact <input type="checkbox"/> Custody Seals Samples / COC Checked By: _____ Work Order Logged By: _____ Receipt Comments: _____ Clinical Lab Receipt Temp. 8.1 °C																							



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

December 3, 2025

Erica Mendoza
State Water Resources Control Board - Division of Drinking Water
Imperial District Engineer
2375 Northside Drive, Suite 100
San Diego, CA 92108

SUBJECT: November 2025 Monthly Report of Monitoring for SWTR

Dear Ms. Mendoza,

Attached, please find the November 2025 Monthly Summary of Monitoring for Surface Water Treatment Regulations.

If you have any questions or need additional information please e-mail or call me at the number below. Thank You.

Respectfully,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Heber Public Utility District
Water Plant Chief Operator
frdriguez@heber.ca.gov
(760) 427-4685

**MONTHLY SUMMARY OF MONITORING
FOR SURFACE WATER TREATMENT REGULATIONS**

SYSTEM NAME: HEBER PUBLIC UTILITY DISTRICT SYSTEM NO:1310007-001
TREATMENT PLANT NAME: HEBER WATER PLANT MONTH: November YEAR: 2025

TREATMENT WATER TURBIDITIES EVERY FOUR HOURS (NTU)

DATE	PEAK RAW WATER TURBIDITY	PEAK SETTLED WATER TURBIDITY	MIDNIGHT TO 0400	0400 TO 0800	0800 TO NOON	NOON TO 1600	1600 TO 2000	2000 TO MIDNIGHT	AVERAGE	MINIMUM CT RATIO
1	9.01	.65	.03	.03	.04	.05	.04	.04	.04	35.91
2	8.47	.37	.03	.04	.05	.04	.04	.03	.04	27.29
3	18.80	.66	.04	.05	.05	.05	.06	.04	.05	18.08
4	18.40	.63	.03	.05	.04	.04	.04	.03	.04	26.16
5	45.20	.51	.04	.03	.03	.03	.04	.05	.04	27.93
6	18.20	.67	.05	.04	.03	.03	.03	.06	.04	33.14
7	12.70	.38	.06	.07	.04	.03	.03	.04	.05	33.32
8	10.30	.32	.04	.02	.03	.04	.04	.05	.04	34.38
9	7.02	.82	.04	.03	.04	.03	.03	.03	.03	33.69
10	20.00	.93	.02	.03	.05	.06	.05	.04	.04	33.64
11	8.80	.53	.03	.03	.03	.05	.04	.04	.04	35.97
12	23.00	.83	.03	.03	.05	.05	.04	.03	.04	30.87
13	13.60	.37	.04	.03	.03	.04	.06	.04	.04	32.64
14	11.50	.48	.03	.03	.04	.04	.03	.03	.03	32.64
15	16.90	.37	.03	.04	.06	.21	.08	.06	.08	50.59
16	12.10	.35	.03	.03	.04	.03	.03	.04	.03	54.53
17	10.60	.58	.05	.05	.03	.00	.05	.04	.04	54.37
18	10.50	.57	.03	.04	.06	.04	.04	.04	.04	53.87
19	9.98	.44	.05	.03	.04	.03	.03	.04	.04	44.76
20	10.20	.40	.04	.04	.05	.04	.05	.05	.05	41.58
21	10.60	.36	.03	.03	.04	.03	.02	.03	.03	54.04
22	11.80	.59	.05	.05	.05	.03	.04	.02	.04	49.58
23	9.19	.42	.03	.05	.06	.03	.05	.03	.04	39.67
24	11.40	.66	.03	.03	.04	.03	.04	.02	.03	47.37
25	13.80	1.12	.03	.04	.03	.06	.05	.03	.04	24.31
26	12.30	1.00	.02	.02	.06	.04	.04	.04	.04	35.52
27	10.60	.60	.05	.04	.05	.04	.03	.04	.04	27.61
28	11.40	.56	.05	.03	.04	.06	.04	.03	.04	34.61
29	10.70	.59	.04	.03	.04	.04	.02	.03	.03	33.04
30	8.07	.49	.04	.05	.05	.03	.05	.05	.05	26.44
31										
AVE	13.50	0.58							0.04	36.92

If a continuous monitoring turbidimeter is used, determine the discrete turbidity value for the same times during each four hour period.

Total No. of Samples: 180 No. of Readings < 0.25 NTU; 180
% Readings < 0.25 NTU = $\frac{\text{No. Readings} < 0.25 \text{ NTU}}{\text{Total No. of Samples}} \times 100 = 100\%$

MEETS STANDARD (i.e. MORE THAN 95% OF READINGS ARE \leq 0.25 NTU) (Y / N)? Y
AVERAGE PERCENT REDUCTION DURING THE MONTH = $\frac{\text{AVERAGE RAW NTU} - \text{AVERAGE EFFLUENT NTU}}{\text{AVERAGE RAW NTU}} \times 100 = 99.7\%$

MEETS STANDARD (i.e. REDUCTION IS GREATER THAN 80%) (Y / N) Y
95th PERCENTILE VALUE (95% OF ALL TURBIDITY READINGS ARE LESS THAN THIS VALUE)
OF ALL TURBIDITY READINGS: .06 NTU'S

Nov-25

Heber PUD 1310007 Inactivation

0.75 & 1.7 Reservoirs in Series

Filtration Giardia Removal Credit 2.5
 Filtration Virus Removal Credit 2

	Value	Corresponding CT Ratio
Max Q	1181	0.50
Min Volume	504,133	2.00
Min Residual	1.03	0.50
Avg CT Ratio	36.49	
Min CT Ratio	18.08	

Date	Time	residual ppm	pH	Temp (c)	Q gpm	WSE	1.7 Reservoir Volume (gal)	1.7 Reservoir T10	0.75 Reservoir Volume (gal)	0.75 Reservoir T10	CT actual	CT Required	Log G Inactivation Rqd	Log V Inactivation Rqd	CT (G) Ratio	Log G Inactivation Achieved	Log V Inactivation Achieved	Met Standard
11/1/2025	0800	1.31	7.79	23	847	23.9	1,432,294	0.03	611,614	0.35	397.5	11.1	0.5	2	35.91	21.3	692.1	Yes
11/2/2025	0800	1.19	7.76	24	1050	22.6	1,354,387	0.03	578,346	0.35	275.5	10.1	0.5	2	27.29	16.8	514.8	Yes
11/3/2025	0800	1.03	7.78	23	1130	19.7	1,180,594	0.03	504,133	0.35	193.1	10.7	0.5	2	18.08	12.0	336.1	Yes
11/4/2025	0800	1.5	7.8	24	1144	19.7	1,180,594	0.03	504,133	0.35	277.8	10.6	0.5	2	26.16	16.3	519.2	Yes
11/5/2025	0800	1.47	7.76	23	1066	21	1,258,501	0.03	537,401	0.35	311.4	11.2	0.5	2	27.93	17.1	542.1	Yes
11/6/2025	0800	1.43	7.71	23	937	22	1,318,429	0.03	562,992	0.35	361.1	10.9	0.5	2	33.14	19.8	628.6	Yes
11/7/2025	0800	1.79	7.74	23	1152	22.9	1,372,365	0.03	586,023	0.35	382.7	11.5	0.5	2	33.32	20.1	666.2	Yes
11/8/2025	0800	1.25	7.75	24	865	22.4	1,342,401	0.03	573,228	0.35	348.1	10.1	0.5	2	34.38	20.5	650.6	Yes
11/9/2025	0800	1.33	7.74	23	881	22.6	1,354,387	0.03	578,346	0.35	366.9	10.9	0.5	2	33.69	20.1	638.8	Yes
11/10/2025	0800	1.46	7.73	23	945	22.3	1,336,408	0.03	570,669	0.35	370.5	11.0	0.5	2	33.64	20.1	645.0	Yes
11/11/2025	0800	1.64	7.73	22	962	23.6	1,414,315	0.03	603,937	0.35	432.7	12.0	0.5	2	35.97	21.3	701.6	Yes
11/12/2025	0800	1.45	7.73	23	1033	22.5	1,348,394	0.03	575,787	0.35	339.7	11.0	0.5	2	30.87	18.7	591.3	Yes
11/13/2025	0800	1.41	7.71	23	953	22.3	1,336,408	0.03	570,669	0.35	354.8	10.9	0.5	2	32.64	19.6	617.7	Yes
11/14/2025	0800	1.5	7.69	23	1052	23.2	1,390,344	0.03	593,700	0.35	355.8	10.9	0.5	2	32.64	19.6	619.3	Yes
11/15/2025	0800	1.49	7.71	22	602	22.3	1,336,408	0.03	570,669	0.35	593.6	11.7	0.5	2	50.59	28.9	962.6	Yes
11/16/2025	0800	2	7.73	22	708	22.5	1,348,394	0.03	575,787	0.35	683.6	12.5	0.5	2	54.53	31.4	1108.5	Yes
11/17/2025	0800	2.44	7.75	22	825	22.7	1,360,379	0.03	580,905	0.35	722.0	13.3	0.5	2	54.37	31.9	1170.9	Yes
11/18/2025	0800	2.39	7.74	21	753	22.2	1,330,415	0.03	568,110	0.35	757.8	14.1	0.5	2	53.87	31.5	1144.7	Yes
11/19/2025	0800	1.83	7.75	21	737	22.2	1,330,415	0.03	568,110	0.35	592.8	13.2	0.5	2	44.76	26.0	895.5	Yes
11/20/2025	0800	1.73	7.76	20	707	22.2	1,330,415	0.03	568,110	0.35	584.2	14.1	0.5	2	41.58	24.2	822.0	Yes
11/21/2025	0800	1.89	7.77	19	556	22.7	1,360,379	0.03	580,905	0.35	829.9	15.4	0.5	2	54.04	30.8	1087.6	Yes
11/22/2025	0800	1.55	7.83	19	503	22.6	1,354,387	0.03	578,346	0.35	749.0	15.1	0.5	2	49.58	28.3	981.6	Yes
11/23/2025	0800	1.34	7.79	19	550	22	1,318,429	0.03	562,992	0.35	576.4	14.5	0.5	2	39.67	23.1	755.4	Yes
11/24/2025	0800	1.56	7.79	19	542	22.8	1,366,372	0.03	583,464	0.35	705.8	14.9	0.5	2	47.37	27.1	924.9	Yes
11/25/2025	0800	1.4	7.81	19	933	22.2	1,330,415	0.03	568,110	0.35	358.3	14.7	0.5	2	24.31	15.1	469.4	Yes
11/26/2025	0800	1.32	7.79	19	634	23	1,378,358	0.03	588,582	0.35	515.0	14.5	0.5	2	35.52	20.9	674.9	Yes
11/27/2025	0800	1.21	7.79	20	806	22.9	1,372,365	0.03	586,023	0.35	369.7	13.4	0.5	2	27.61	16.9	520.1	Yes
11/28/2025	0800	1.18	7.79	20	643	23.4	1,402,329	0.03	598,818	0.35	461.8	13.3	0.5	2	34.61	20.5	649.7	Yes
11/29/2025	0800	1.09	7.84	20	617	23.4	1,402,329	0.03	598,818	0.35	444.6	13.5	0.5	2	33.04	19.8	625.5	Yes
11/30/2025	0800	1.06	7.85	19	710	23.7	1,420,308	0.03	606,496	0.35	380.5	14.4	0.5	2	26.44	16.3	498.6	Yes

Incidents of turbidity greater than 1.0 NTU

Date of Incident					
Value		N/A			
Duration					

Total number of incidents where turbidity is > 1.0 NTU: None > 5.0 NTU: None
Meet Standards (i.e. NTU is not > 1.0 for more than eight consecutive hours) (Y/N): Yes

After placing the filter back into service after any interruption (e.g. backwashing), did the filter effluent comply with the following criteria:

- a: <= 2.0 NTU after all events (Y/N)? Yes
- b: <= 1.0 NTU after 90% events (Y/N)? Yes
- c: <= 0.5 NTU after four hours (Y/N)? Yes

Indicate the date that the turbidimeters that are used for regulatory monitoring purposes were calibrated:

Date	Which Turbidimeter	Which standards used, primary or secondary	Date	Which Turbidimeter	Which standards used, primary or secondary
11/17/2025	1720 E	Primary			
11/17/2025	Hach 2100Q	Secondary			

DISINFECTION PROCESS DATA

Disinfectant residual type (check one): free chlorine X
 combined chlorine _____
 other _____

Incidents of chlorine residuals less than 0.2 ppm at the plant effluent:

Date of Incident					
Duration					
Date Dept. Notified		N/A			

Total number of incidents where residual is < 0.2 ppm: None
Meet Standard (i.e. is not less than 0.2 ppm for more than four hours (Y/N)? Yes

Number of distribution system residual samples collected:	8
Number of distribution system samples for HPC only:	0
Total number of residual and/or HPC samples collected:	8
Number of samples with no detectable residual and HPC is not measured:	0
Number of samples with no residual and HPC > 500 CFU/mL:	0
Number of samples for HPC only and HPC > 500 CFU/mL:	0
Total number of samples with no residual and/or HPC > 500 CFU/mL:	0

Compute V:

Where V = [1 - (Total No. of samples with no residual and/or HPC > 500)/(Total No. of residual and/or HPC samples collected)] x 100

V = 100.0%
Meets Standard (i.e. V >= 95%) (Y/N)? Yes

SUMMARY OF WATER QUALITY COMPLAINTS

General Complaints:

Type of Complaint	Number	Corrective Actions Taken
Taste/Odor	0	None
Color	0	None
Turbidity	0	None
Suspended Solids	0	None
Other	0	None

Reports of Gastrointestinal Illness (attach additional sheets if necessary):

Person Reporting	Date	Corrective Actions Taken

Attach an explanation of any failure of the performance standards or operating criteria and corrective action taken or planned.

Signature:



Date:

12/3/2025



County of Imperial Public Health Laboratory
Environmental Test Result Form

SYSTEM

SAMPLE # 273157

System:	Heber Public Utility District	Sample Type:	Routine	Other:	45.2NTU
Collection Site:	Raw Gate H-1	Source:	Water, Raw	Collected by:	Guillermo Verdugo
Collection Point:	Site #15	Collected:	11/05/2025 10:00 AM	Received by:	Sarai Rosas
		Received:	11/05/2025 00:00		

TEST RESULTS, CONCLUSIONS and COMMENTS:

Quanti-Tray (Test Method: SM 9223A, B) Sample Dilution: 1:1	Total Coliform		E-Coli	
	MPN /100ml	Conclusion	MPN /100ml	Conclusion
	>2419.2	PRESENT	61.7	PRESENT

Ready	Leticia Lopez	Approved	Holly Maag	Printed	Holly Maag
Date	11/6/2025 3:51:00 PM	Date	11/06/2025 09:32:00 PM	Date	11/06/2025 09:33:00 PM

REQUESTED BY:

Heber Public Utility District
 1078 Dogwood Rd.
 Heber, CA 92249

LABORATORY:

ELAP #: 1773
 Director: Holly Maag B.S. M.H.A.
 Imperial County Public Health Laboratory
 935 Broadway
 El Centro, CA 92243
 Phone: (442)265-1427
 Fax: (442)265-1472

Heber PUD Backwash Recycled Water Percentage

Month	November	Year	2025
Date	Total Recycled Water Flow, gallons	Total Plant Flow, gallons	Percent Return
1	15000	740600	2%
2	29800	280900	11%
3	43900	1037500	4%
4	42100	1143000	4%
5	23700	1061800	2%
6	38500	1063800	4%
7	38600	874900	4%
8	47200	854800	6%
9	8700	780300	1%
10	46900	1180500	4%
11	39300	651500	6%
12	38800	869800	4%
13	45100	960100	5%
14	7400	476600	2%
15	38300	759600	5%
16	44100	825800	5%
17	7600	571400	1%
18	35400	666600	5%
19	15600	646900	2%
20	37800	727900	5%
21	37500	502100	7%
22	6700	462100	1%
23	37900	821100	5%
24	10100	422700	2%
25	43100	7444200	1%
26	29100	643300	5%
27	16500	660600	2%
28	36800	643000	6%
29	36900	686500	5%
30	14700	635000	2%
31			
Total		Average	4%

Heber PUD

WEEKLY GENERAL PHYSICAL SAMPLES

OPERATOR	DATE	SITE #	COLOR	ODOR	TURBIDITY
G.V. RAW	11/5/25	15	3	3	45.2 NTU
G.V. TAP	11/5/25	1	NONE	NONE	0.19 NTU
G.V. TAP	11/5/25	2	NONE	NONE	0.16 NTU
G.V. TAP	11/5/25	3	NONE	NONE	0.17 NTU
G.V. TAP	11/5/25	4	NONE	NONE	0.16 NTU
G.V. TAP	11/19/25	5	NONE	NONE	0.16 NTU
G.V. TAP	11/19/25	6	NONE	NONE	0.17 NTU
G.V. TAP	11/19/25	7	NONE	NONE	0.15 NTU
G.V. TAP	11/19/25	8	NONE	NONE	0.16 NTU



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

December 3, 2025

Erica Mendoza
State Water Resources Control Board - Division of Drinking Water
Imperial District Engineer
2375 Northside Drive, Suite 100
San Diego, CA 92108

SUBJECT: October 2025 Monthly TCR report

Dear Ms. Mendoza,

Attached, please find the November 2025 Monthly TCR report.

If you have any questions or need additional information please e-mail or call me at the number below. Thank You.

Respectfully,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Heber Public Utility District
Water Plant Chief Operator
frdriguez@heber.ca.gov
(760) 427-4685

MONTHLY SUMMARY OF REVISED TOTAL COLIFORM RULE DISTRIBUTION SYSTEM MONITORING
(For public water systems serving more than 400 service connections OR 1,000 persons, OR wholesaler systems)
(Includes triggered source monitoring reporting for Groundwater Rule compliance)

System Name <p align="center">Heber Public Utility District</p>	System Number <p align="center">1310007</p>
Sampling Period <p align="center">November</p>	Year <p align="center">2025</p>

	Number Required	Number Collected	Number Total Coliform Positives	Number E.coli Positives
1. Routine Samples (see note 1)	8	8	0	0
2. Repeat Samples following samples that are Total Coliform Positive and <i>E.coli</i> Negative (see notes 2, 10 and 11)		0	0	0
3. Repeat Samples following Routine Samples that are Total Coliform Positive and <i>E. coli</i> Positive (see notes 2, 3, 10 and 11)		0	0	0
4. Coliform Treatment Technique (TT) Trigger Exceedance & <i>E.coli</i> MCL Computation for TC/ <i>E. coli</i> Positive Samples				
a. Totals (sum of columns)	8	8	0	0
b. If 40 or more samples collected in month, determine percent of samples that are total coliform positive [(total number positive/total number collected) x 100] =	N/A	%		
c. Did the system violate the <i>E. coli</i> MCL (see notes 2 through 5)?			<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Did the system exceed... ..a Level 2 Coliform TT trigger? (see notes 2, 3, 4, 5 and 6 for trigger info)			<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
<i>If yes, see note 8 below.</i>				
...a Level 1 Coliform TT trigger? (see note 7 for trigger info)			<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
<i>If yes, see note 9 below.</i>				
5. Triggered Source Samples per Groundwater Rule (see notes 12 and 13)		N/A	N/A	N/A
6. Invalidated Samples (Note what samples, if any, were invalidated; the lab who authorized the invalidation; and when replacement samples were collected. Attach additional sheets, if necessary.)				N/A

7. Summary Completed By:

Name/Signature 	Title <p align="center">Chief Operator</p>	Date <p align="center">12/3/2025</p>
--------------------	---	---

NOTES AND INSTRUCTIONS:

1. Routine samples include:
 - a. Samples required pursuant to 22 CCR Section 64423 and any additional samples required by an approved routine sample siting plan established pursuant to 22 CCR Section 64422.
 - b. Extra samples for systems with high source water turbidities that are using surface water or groundwater under direct influence of surface water and do not practice filtration in compliance with regulations;
- Notes 2-5 (boxed entries) are *E. coli* MCL violations and require immediate notification to the Division (22 CCR, Section 64426.1):
2. Any *E.coli* positive repeat following a total coliform positive sample.
3. A total coliform positive repeat, following an *E.coli* positive routine sample.
4. Failure to take all required repeat samples following an *E. coli* positive routine sample.
5. Failure to test for *E. coli* when any repeat sample tests positive for total coliform
6. Second Level 1 coliform treatment technique trigger exceedance in a rolling 12-month period.
7. **Level 1 Coliform Treatment Technique (TT) Triggers:**
 - a. For systems collecting less than 40 samples, if two or more samples are total coliform positive, then the TT is exceeded and a Level 1 Assessment is required.
 - b. For systems collecting 40 or more samples, if more than 5.0 percent of samples collected are total coliform positive, then the TT is exceeded and a Level 1 Assessment is required.
 - c. **If a trigger is exceeded as a result of a total coliform positive repeat sample, the system must notify the Division by the end of business day, section 64424(c)**
8. Contact the Division as soon as practical to arrange for the Division to conduct a Level 2 Assessment of the water system. The water system shall complete a Level 2 Assessment and submit it to the Division within 30 days of learning of the trigger exceedance.
9. Conduct a Level 1 Assessment as soon as practical that covers the minimum elements (22 CCR, Section 64426.8 (a)(2)). Submit the report to the Division within 30 days of learning of the trigger exceedance.
10. Positive results and their associated repeat samples are to be tracked on the Coliform Monitoring Worksheet.
11. Repeat samples must be collected within 24 hours of being notified of the positive results. At least 3 repeat samples must be collected for each total coliform positive sample.
12. For systems subject to the Groundwater Rule: Positive results and the associated triggered source samples are to be tracked on the Coliform Monitoring Worksheet.
13. For triggered sample(s) required as a result of a total coliform routine positive sample, an *E.coli* -positive triggered sample (boxed entry) **requires immediate notification to the Division, Tier 1 public notification, and corrective action.**



County of Imperial Public Health Laboratory
Environmental Test Result Form

SYSTEM

SAMPLE # 273153

System: Heber Public Utility District	Sample Type: Routine	Chlorine: 0.78 mg/L
Collection Site: 23 W.Sparrow St	Source: Water	Other: .19NTU
Collection Point: Site #1	Collected: 11/05/2025 11:10 AM	Collected by: Guillermo Verdugo
	Received: 11/05/2025 00:00	Received by: Sarai Rosas

TEST RESULTS, CONCLUSIONS and COMMENTS:

Presence/Absence (Test Method: SM 9223A, B)	Total Coliform		E-Coli	
		Conclusion		Conclusion
		Absent		Absent

Ready	Leticia Lopez	Approved	Holly Maag	Printed	Holly Maag
Date	11/6/2025 3:50:00 PM	Date	11/06/2025 09:30:00 PM	Date	11/06/2025 09:31:10 PM

REQUESTED BY:

Heber Public Utility District
 1078 Dogwood Rd.
 Heber, CA 92249

LABORATORY:

ELAP #: 1773
 Director: Holly Maag B.S. M.H.A.
 Imperial County Public Health Laboratory
 935 Broadway
 El Centro, CA 92243
 Phone: (442)265-1427
 Fax: (442)265-1472



County of Imperial Public Health Laboratory
Environmental Test Result Form

SYSTEM

SAMPLE # 273154

System:	Heber Public Utility District	Sample Type:	Routine	Chlorine:	0.75 mg/L
Collection Site:	Jr.High School	Source:	Water	Other:	.16NTU
Collection Point:	Site #2	Collected:	11/05/2025 10:25 AM	Collected by:	Guillermo Verdugo
		Received:	11/05/2025 00:00	Received by:	Sarai Rosas

TEST RESULTS, CONCLUSIONS and COMMENTS:

Presence/Absence (Test Method: SM 9223A, B)	Total Coliform		E-Coli	
		Conclusion		Conclusion
		Absent		Absent

Ready	Leticia Lopez	Approved	Holly Maag	Printed	Holly Maag
Date	11/6/2025 3:50:00 PM	Date	11/06/2025 09:30:00 PM	Date	11/06/2025 09:31:10 PM

REQUESTED BY:

Heber Public Utility District
 1078 Dogwood Rd.
 Heber, CA 92249

LABORATORY:

ELAP #: 1773
 Director: Holly Maag B.S. M.H.A.
 Imperial County Public Health Laboratory
 935 Broadway
 El Centro, CA 92243
 Phone: (442)265-1427
 Fax: (442)265-1472



County of Imperial Public Health Laboratory
Environmental Test Result Form

SYSTEM

SAMPLE # 273155

System:	Heber Public Utility District	Sample Type:	Routine	Chlorine:	0.32 mg/L
Collection Site:	189 Gill Rd	Source:	Water	Other:	.17NTU
Collection Point:	Site #3	Collected:	11/05/2025 10:55 AM	Collected by:	Guillermo Verdugo
		Received:	11/05/2025 00:00	Received by:	Sarai Rosas

TEST RESULTS, CONCLUSIONS and COMMENTS:

Presence/Absence (Test Method: SM 9223A, B)	Total Coliform		E-Coli	
		Conclusion		Conclusion
		Absent		Absent

Ready	Leticia Lopez	Approved	Holly Maag	Printed	Holly Maag
Date	11/6/2025 3:50:00 PM	Date	11/06/2025 09:30:00 PM	Date	11/06/2025 09:31:10 PM

REQUESTED BY:

Heber Public Utility District
 1078 Dogwood Rd.
 Heber, CA 90049

LABORATORY:

ELAP #: 1773
 Director: Holly Maag B.S. M.H.A.
 Imperial County Public Health Laboratory
 935 Broadway
 El Centro, CA 92243
 Phone: (442)265-1427
 Fax: (442)265-1472



County of Imperial Public Health Laboratory
Environmental Test Result Form

SYSTEM

SAMPLE # 273156

System:	Heber Public Utility District	Sample Type:	Routine	Chlorine:	0.79 mg/L
Collection Site:	Ormat Geothermal	Source:	Water	Other:	.16NTU
Collection Point:	Site #4	Collected:	11/05/2025 10:45 AM	Collected by:	Guillermo Verdugo
		Received:	11/05/2025 00:00	Received by:	Sarai Rosas

TEST RESULTS, CONCLUSIONS and COMMENTS:

Presence/Absence (Test Method: SM 9223A, B)	Total Coliform		E-Coli	
		Conclusion		Conclusion
		Absent		Absent

Ready	Leticia Lopez	Approved	Holly Maag	Printed	Holly Maag
Date	11/6/2025 3:50:00 PM	Date	11/06/2025 09:30:00 PM	Date	11/06/2025 09:31:10 PM

REQUESTED BY:

Heber Public Utility District
 1078 Dogwood Rd.
 , CA 92249

LABORATORY:

ELAP #: 1773
 Director: Holly Maag B.S. M.H.A.
 Imperial County Public Health Laboratory
 935 Broadway
 El Centro, CA 92243
 Phone: (442)265-1427
 Fax: (442)265-1472



County of Imperial Public Health Laboratory Environmental Test Result Form

SYSTEM

SAMPLE # 273388

System:	Heber Public Utility District	Sample Type:	Routine	Chlorine:	1.18 mg/L
Collection Site:	Heber Village Apt	Source:	Water	Other:	.16NTU
Collection Point:	Site #5	Collected:	11/19/2025 11:00 AM	Collected by:	Guillermo Verdugo
		Received:	11/19/2025 00:00	Received by:	Letty Lopez

TEST RESULTS, CONCLUSIONS and COMMENTS:

Presence/Absence (Test Method: SM 9223A, B)	Total Coliform		E-Coli	
		Conclusion		Conclusion
		Absent		Absent

Ready	Sarai Rosas	Approved	Holly Maag	Printed	Holly Maag
Date	11/20/2025 2:21:00 PM	Date	11/20/2025 04:59:00 PM	Date	11/20/2025 04:59:24 PM

REQUESTED BY:

Heber Public Utility District
1078 Dogwood Rd.
Heber, CA 92249

LABORATORY:

ELAP #: 1773
Director: Holly Maag B.S. M.H.A.
Imperial County Public Health Laboratory
935 Broadway
El Centro, CA 92243
Phone: (442)265-1427
Fax: (442)265-1472



County of Imperial Public Health Laboratory

Environmental Test Result Form

SYSTEM

SAMPLE # 273389

System: Heber Public Utility District	Sample Type: Routine	Chlorine: 0.71 mg/L
Collection Site: 71 McCabe Road	Source: Water	Other: .17NTU
Collection Point: Site #6	Collected: 11/19/2025 11:25 AM	Collected by: Guillermo Verdugo
	Received: 11/19/2025 00:00	Received by: Letty Lopez

TEST RESULTS, CONCLUSIONS and COMMENTS:

Presence/Absence (Test Method: SM 9223A, B)	Total Coliform		E-Coli	
		Conclusion		Conclusion
		Absent		Absent

Ready	Sarai Rosas	Approved	Holly Maag	Printed	Holly Maag
Date	11/20/2025 2:21:00 PM	Date	11/20/2025 04:59:00 PM	Date	11/20/2025 04:59:25 PM

REQUESTED BY:

Heber Public Utility District
 1078 Dogwood Rd.
 Heber, CA 92249

LABORATORY:

ELAP #: 1773
 Director: Holly Maag B.S. M.H.A.
 Imperial County Public Health Laboratory
 935 Broadway
 El Centro, CA 92243
 Phone: (442)265-1427
 Fax: (442)265-1472



County of Imperial Public Health Laboratory Environmental Test Result Form

SYSTEM

SAMPLE # 273390

System:	Heber Public Utility District	Sample Type:	Routine	Chlorine:	1.14 mg/L
Collection Site:	1156 Harmony Way	Source:	Water	Other:	.15NTU
Collection Point:	Site #7	Collected:	11/19/2025 11:40 AM	Collected by:	Guillermo Verdugo
		Received:	11/19/2025 00:00	Received by:	Letty Lopez

TEST RESULTS, CONCLUSIONS and COMMENTS:

Presence/Absence (Test Method: SM 9223A, B)	Total Coliform		E-Coli	
		Conclusion		Conclusion
		Absent		Absent

Ready	Sarai Rosas	Approved	Holly Maag	Printed	Holly Maag
Date	11/20/2025 2:21:00 PM	Date	11/20/2025 04:59:00 PM	Date	11/20/2025 04:59:25 PM

REQUESTED BY:

Heber Public Utility District
1078 Dogwood Rd.
Heber, CA 92249

LABORATORY:

ELAP #: 1773
Director: Holly Maag B.S. M.H.A.
Imperial County Public Health Laboratory
935 Broadway
El Centro, CA 92243
Phone: (442)265-1427
Fax: (442)265-1472



County of Imperial Public Health Laboratory

Environmental Test Result Form

SYSTEM

SAMPLE # 273391

System:	Heber Public Utility District	Sample Type:	Routine	Chlorine:	1.17 mg/L
Collection Site:	55 Black Horse Drive	Source:	Water	Other:	.16NTU
Collection Point:	Site #8	Collected:	11/19/2025 11:50 AM	Collected by:	Guillermo Verdugo
		Received:	11/19/2025 00:00	Received by:	Letty Lopez

TEST RESULTS, CONCLUSIONS and COMMENTS:

Presence/Absence (Test Method: SM 9223A, B)	Total Coliform		E-Coli	
		Conclusion		Conclusion
		Absent		Absent

Ready	Sarai Rosas	Approved	Holly Maag	Printed	Holly Maag
Date	11/20/2025 2:21:00 PM	Date	11/20/2025 04:59:00 PM	Date	11/20/2025 04:59:25 PM

REQUESTED BY:

Heber Public Utility District
 1078 Dogwood Rd.
 Heber, CA 92249

LABORATORY:

ELAP #: 1773
 Director: Holly Maag B.S. M.H.A.
 Imperial County Public Health Laboratory
 935 Broadway
 El Centro, CA 92243
 Phone: (442)265-1427
 Fax: (442)265-1472

California State Water Resources Control Board

DROUGHT REPORT

PWSID: CA1310007

Water System Name: HEBER PUBLIC UTILITY DISTRICT

Reporting Period: 11/01/2025 - 11/30/2025

Reporting Due Date: 01/31/2026

Report Created Date: 12/03/2025

WATER SHORTAGE

Experiencing a severe water shortage: No

Estimated date of when a severe water shortage may begin: Severe water shortage not expected

Do you have a Water Shortage Contingency Plan (or Drought Planning Elements)?: Yes

Website link to Water Shortage Contingency Plan: https://heber.ca.gov/sites/default/files/site_documents/HPUD-SB552-water-conservation-plan-Final.pdf

Upload Water Shortage Contingency Plan: HPUD Draft SB552 water conservation plan LF with MC.pdf

Adoption date of Plan: 01/01/2023

What equivalent level percent source reduction of your Water Shortage Contingency Plan have you invoked?: No Shortage Level Invoked

Comments:

SOURCE REPORTING

CENTRAL MAIN CANAL, GATE H1

Source Information:

- **Facility ID:** 003
- **Facility Type:** Consecutive Connection
- **Water Type:** Surface Water
- **Facility Availability:** Permanent
- **Activity Status:** Active
- **Maximum Capacity:** 6,000,000.00000000
- **Maximum Capacity Unit of Measure:** Gallons per Day (GPD)

- **Maximum Contractual Daily Rate:** Missing Information
- **Maximum Contractual Daily Rate Unit of Measure:** Gallons per Day (GPD)
- **Maximum Contractual Monthly Volume:** Missing Information
- **Maximum Contractual Monthly Volume Unit of Measure:** Missing Information
- **Maximum Contractual Annual Volume:** Missing Information
- **Maximum Contractual Annual Volume Unit of Measure:** Missing Information
- **Ability to utilize the intertie:** Missing Information
- **Seller Treatment:** Not Treated by Seller
- **Seasonal Availability Start Date:** Missing Information
- **Seasonal Availability End Date:** Missing Information

Did you utilize this source during the reporting period?: Yes

Potable Amount Received During Reporting Period: 22.73900000

Potable Amount Received During Reporting Period Date Measured: 11/30/2025

Potable Amount Received During Reporting Period Unit of Measure: Million Gallons (MG)

Comments:

DOGWOOD - GATE 37A

Source Information:

- **Facility ID:** 001
- **Facility Type:** Consecutive Connection
- **Water Type:** Surface Water
- **Facility Availability:** Emergency
- **Activity Status:** Active
- **Maximum Capacity:** 2,000,000.00000000
- **Maximum Capacity Unit of Measure:** Million Gallons per Day (MGD)
- **Maximum Contractual Daily Rate:** Missing Information
- **Maximum Contractual Daily Rate Unit of Measure:** Gallons per Day (GPD)
- **Maximum Contractual Monthly Volume:** Missing Information
- **Maximum Contractual Monthly Volume Unit of Measure:** Missing Information
- **Maximum Contractual Annual Volume:** Missing Information
- **Maximum Contractual Annual Volume Unit of Measure:** Missing Information
- **Ability to utilize the intertie:** Currently Unavailable

- **Seller Treatment:** Not Treated by Seller
- **Seasonal Availability Start Date:** Missing Information
- **Seasonal Availability End Date:** Missing Information

Did you utilize this source during the reporting period?: No

Potable Amount Received During Reporting Period: 0.00000000

Potable Amount Received During Reporting Period Date Measured: 11/30/2025

Potable Amount Received During Reporting Period Unit of Measure: Gallons (G)

Comments:

TOTAL PRODUCTION DURING REPORTING PERIOD (gallons): 22,739,000.00

SUPPLY & DEMAND

ABOUT

Does your system supply or deliver non-potable water to customers or other water systems?: No

Does your system supply or deliver recycled water to customers or other water systems?: No

POTABLE SUPPLY

Unit of Measure: Gallons (G)

POTABLE SELF-PRODUCED

TOTAL Potable Self-Produced	Preliminary Estimate?
0	No

POTABLE EXTERNALLY-SOURCED

Consecutive Connection	Consecutive Connection Obtained From (Water Systems Only)	Bottled Water Reliance	TOTAL Potable Externally-Sourced	Preliminary Estimate?
22,739,000	CA1310014 - IMPERIAL IRRIGATION DISTRICT	No	22,739,000	No

TOTAL POTABLE SUPPLY

TOTAL Potable Supply	Preliminary Estimate?
22,739,000	No

POTABLE SUPPLY COMMENTS:

POTABLE DEMAND

Do you meter the volume of potable water delivered to your individual customers?: Yes

Unit of Measure: Gallons (G)

POTABLE RESIDENTIAL DEMAND

Residential Single-Family	Residential Multi-Family	TOTAL Residential Demand	Population Served	Residential Gallons per Capita per Day (R-GPCD)	Preliminary Estimate?
16,469,741	1,561,585	18,031,326	6,979	89.09	No

POTABLE NON-RESIDENTIAL DEMAND

Commercial & Institutional	Metered Irrigation of Commercial, Industrial, or Institutional Landscapes	Industrial	Agriculture	Other Non-Residential Demand	Total Non-Residential Demand	Preliminary Estimate?
288,302	0	909,446	0	2,240,769	3,438,517	No

POTABLE WATER DELIVERED TO OTHER WATER SYSTEM (S)

Volume Sold or Delivered to Other Water System(s)	Sold or Delivered To (Water Systems Only)	Preliminary Estimate?
0		No

TOTAL POTABLE DEMAND

TOTAL Potable Demand	Preliminary Estimate?
21,469,843	No

POTABLE DEMAND COMMENTS:

TOTAL REPORT SUMMARY

POTABLE SUPPLY & DEMAND (IN GALLONS)

TOTAL Potable Supply	TOTAL Potable Demand	Preliminary Supply Estimate?	Preliminary Demand Estimate?	Potable Supply and Demand Difference
22,739,000	21,469,843	No	No	1,269,157

POTABLE SUPPLY & DEMAND COMMENTS:

ESTIMATED POTABLE WATER LOSS

Estimated Potable Water Loss (in gallons)
2,273,900

ESTIMATED POTABLE WATER LOSS COMMENTS:

MAXIMUM DAY DEMAND (MDD)

Estimated Maximum Day Demand (in gallons): 1,136,950

Maximum Day Demand (in gallons): 1

Maximum Day Demand Date: 11/04/2025

MAXIMUM DAY DEMAND (MDD) COMMENTS:

ANNUAL SUPPLY (IN GALLONS)

Month	Consecutive Connection	TOTAL Potable Supply
January	18,879,000	18,879,000
February	18,659,000	18,659,000
March	22,272,000	22,272,000
April	26,462,000	26,462,000
May	32,637,000	32,637,000
June	34,294,000	34,294,000
July	37,020,000	37,020,000
August	36,003,000	36,003,000
September	31,146,000	31,146,000
October	25,334,000	25,334,000
November	22,739,000	22,739,000
December		0
TOTAL	305,445,000	305,445,000

Month	TOTAL Supply
January	18,879,000
February	18,659,000
March	22,272,000
April	26,462,000
May	32,637,000
June	34,294,000
July	37,020,000
August	36,003,000
September	31,146,000
October	25,334,000
November	22,739,000
December	0
TOTAL	305,445,000

ANNUAL DEMAND (IN GALLONS)

Month	Residential Single-Family	Residential Multi-Family	Commercial & Institutional	Metered Irrigation of Commercial, Industrial, or Institutional Landscapes	Industrial	Agriculture	Other Non-Residential Demand	Volume Sold or Delivered to Other Water System(s)	TOTAL Potable Demand
January	13,283,773	1,436,477	252,344	0	1,063,406	0	3,121,768	0	19,157,768
February	14,046,028	1,439,669	278,815	0	1,822,943	0	2,493,483	0	20,080,938
March	14,256,173	1,627,009	286,303	0	1,003,962	0	3,217,015	0	20,390,462
April	17,961,801	1,598,827	295,966	0	1,038,828	0	4,242,287	0	25,137,709
May	19,337,007	1,800,499	288,376	0	1,204,937	0	5,100,004	0	27,730,823
June	21,963,645	1,864,312	309,838	0	1,016,053	0	5,002,948	0	30,156,796
July	24,246,199	2,122,352	808,547	0	1,017,120	0	2,247,114	0	30,441,332
August	23,878,388	2,204,481	521,639	0	1,096,167	0	7,590,889	0	35,291,564
September	19,704,455	1,823,497	462,768	0	1,169,819	0	6,320,788	0	29,481,327
October	17,484,137	1,538,332	326,651	0	626,019	0	3,365,304	0	23,340,443
November	16,469,741	1,561,585	288,302	0	909,446	0	2,240,769	0	21,469,843
December									0
TOTAL	202,631,347	19,017,040	4,119,549	0	11,968,700	0	44,942,369	0	282,679,005

Month	TOTAL Demand
January	19,157,768
February	20,080,938
March	20,390,462
April	25,137,709
May	27,730,823
June	30,156,796
July	30,441,332
August	35,291,564
September	29,481,327
October	23,340,443
November	21,469,843
December	0
TOTAL	282,679,005



HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report
 Billing Period :OCTOBER 19, 2025 thru NOVEMBER 18, 2025

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Nov-24	24,426,000	24,006,473	1,978,551	-1,559,024	14,475,000	\$ 137,174.61	\$ 116,866.31	\$ 59,398.74	166 Accounts
Dec-24	19,145,000	21,611,874	1,346,649	-3,813,523	13,666,000	\$ 134,472.59	\$ 116,784.19	\$ 59,569.57	166 Accounts
Jan-25	18,836,000	19,157,768	1,531,243	-1,853,011	12,692,000	\$ 132,753.07	\$ 116,527.28	\$ 59,550.93	166 Accounts
Feb-25	19,618,000	20,080,938	1,664,481	-2,127,419	13,489,000	\$ 132,926.63	\$ 116,552.04	\$ 59,527.34	166 Accounts
Mar-25	20,043,000	20,390,552	2,187,885	-2,535,437	12,360,000	\$ 130,169.73	\$ 116,705.53	\$ 59,484.98	166 Accounts
Apr-25	25,993,000	25,137,709	2,961,623	-2,106,332	13,863,000	\$ 135,876.87	\$ 116,928.52	\$ 59,542.32	167 Accounts
May-25	30,161,000	27,730,823	3,556,069	-1,125,892	13,766,000	\$ 140,716.70	\$ 117,062.63	\$ 59,627.47	170 Accounts
Jun-25	33,319,000	30,156,796	3,031,154	131,050	14,599,000	\$ 148,780.49	\$ 117,216.21	\$ 59,639.17	170 Accounts
Jul-25	35,710,000	30,330,332	412,788	4,966,880	14,157,000	\$ 157,505.88	\$ 117,382.10	\$ 61,603.45	173 Accounts
Aug-25	35,291,564	37,781,000	5,036,022	-2,489,436	14,603,000	\$ 159,459.05	\$ 118,187.81	\$ 61,533.43	173 Accounts
Sep-25	31,146,000	29,481,327	4,340,771	1,664,673	14,943,000	\$ 144,984.94	\$ 121,164.92	\$ 61,518.45	173 Accounts
Oct-25	23,984,000	23,340,443	1,371,609	643,557	13,174,000	\$ 136,318.39	\$ 116,871.77	\$ 61,503.80	173 Accounts
Nov-25	22,739,000	21,469,843	1,101,047	1,269,157	13,178	\$ 134,331.13	\$ 117,937.44	\$ 61,617.85	173 Accounts

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.

Liz German

Liz German
 Office Senior Clerk

12/12/2025

Date