



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H  
Heber CA 92249  
Tel:(760)482-2440 • Fax (760)353-9951  
[www.heber.ca.gov](http://www.heber.ca.gov)

December 9, 2024

Attention: Madeline  
General Manager

Subject: November 2024 Monthly Report

On the billing cycles ending on the 20th of November 24,426,000 gallons of water were used by our consumers, an average of 814,000 gallons was used per day.

On November 21, 2024, collected the monthly Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on December 2, 2024 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 67 ppb for the McCabe site and 54 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

December 9, 2024

Attention: Madeline  
General Manager

Subject: Water Distribution Report November 2024

a) Water breaks (0)

b) Service Leak (0)


c) Work orders (39)

OCC – OCUPANT CHANGE	6
CON - CONNECT	8
SWR- SEWER PLUG UP	1
DIS - DISCONNECT	7
WTR – SERVICE LINE LEAK	2
LEAK - METER LEAK	5
PRSUR – TEST WATER PRESSURE	1
INFO - TEST METER	4
DIRTY - DIRTY/DARK WATER	2
HYDRT – HYDRANT LEAK	2
SC – SERVICE CHANGE	1
TOTAL ALL CODES	39

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



## Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H  
Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951  
[www.heber.ca.gov](http://www.heber.ca.gov)

December 9, 2024

Attention: Madeline Dessert  
General Manager

SUBJECT: Heber W.W.T.P. Operations from October 21, 2024 through November 21, 2024.

- A. Major violations: (NONE)
- B. Minor violations: (NONE)
- C. Major sewer spills: (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning.
- F. Vactor Truck: Vactor truck was used to clean digester and service leaks.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0 miles.
- H. From October 21, 2024 through November 20, 2024: Heber Wastewater Plant received and treated 14.475 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of November 21, 2024.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez".

Edoardo S. Gonzalez  
Wastewater Plant Lead Operator



HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report  
 Billing Period :OCTOBER 21, 2024 thru NOVEMBER 20, 2024

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Nov-23	24,697,000	23,117,991	1,764,615	-185,606	15,743,000	\$ 137,195.23	\$ 117,267.22	\$ 55,685.68	160 Accounts
Dec-23	20,976,000	21,708,288	2,543,739	-3,276,027	14,691,000	\$ 135,839.85	\$ 116,781.70	\$ 55,576.30	160 Accounts
Jan-24	20,638,366	18,135,000	1,825,771	677,595	15,560,000	\$ 134,297.40	\$ 117,302.21	\$ 55,426.19	160 Accounts
Feb-24	15,667,000	16,178,248	2,054,462	-2,565,710	17,779,000	\$ 124,392.83	\$ 116,000.69	\$ 55,382.61	160 Accounts
Mar-24	20,322,000	21,108,650	1,837,250	-2,623,900	16,197,000	\$ 129,995.46	\$ 116,490.45	\$ 56,706.82	160 Accounts
Apr-24	25,549,000	24,474,159	2,026,456	-951,615	16,037,000	\$ 137,142.31	\$ 116,538.21	\$ 57,140.44	159 Accounts
May-24	28,843,000	27,127,172	2,558,028	-842,200	14,607,000	\$ 142,812.36	\$ 117,203.17	\$ 57,081.99	159 Accounts
Jun-24	37,690,000	33,120,546	1,813,047	2,756,407	15,141,000	\$ 164,837.06	\$ 117,141.44	\$ 57,132.60	160 Accounts
Jul-24	39,157,000	35,420,583	2,896,894	839,523	14,417,000	\$ 167,879.73	\$ 117,572.65	\$ 59,335.38	160 Accounts
Aug-24	37,804,000	31,835,694	2,348,695	3,619,611	13,568,000	\$ 157,634.05	\$ 117,426.53	\$ 59,321.68	160 Accounts
Sep-24	36,091,000	32,568,946	2,391,872	1,130,182	14,684,000	\$ 158,946.99	\$ 117,782.09	\$ 59,327.03	166 Accounts
Oct-24	30,006,000	28,543,493	2,209,711	-747,204	17,647,000	\$ 146,026.20	\$ 117,155.53	\$ 59,391.78	166 Accounts
<b>Nov-24</b>	<b>24,426,000</b>	<b>24,006,473</b>	<b>1,978,551</b>	<b>-1,559,024</b>	<b>14,475,000</b>	<b>\$ 137,174.61</b>	<b>\$ 116,866.31</b>	<b>\$ 59,398.74</b>	<b>166 Accounts</b>

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.

Liz German  
 Liz German  
 Office Senior Clerk

12/9/2024  
 Date

## \*\*\*\* TOTALS BY JOB CODE \*\*\*\*

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
INFO - TEST METER	4	1	0	0	0
OCC - OCCUPANT CHANGE	6	0	0	0	0
LEAK - METER LEAK	5	1	0	0	0
DIRTY - DIRTY/DARK WATER	2	0	0	0	0
CON - CONNECT	8	0	0	0	0
WTR - SERVICE LINE LEAK	2	0	0	0	0
MISC - MISC REPORT	0	1	0	0	0
DIS - DISCONNECT	7	0	0	0	13
SWR - SEWER PLUG UP	1	0	0	0	0
PRSUR - TEST WATER PRESSURE	1	0	0	0	0
HYDRT - HYDRANT LEAK	2	0	0	0	0
SC - SERVICE CHANGE	1	0	0	0	0
TOTAL ALL CODES	39	3	0	0	13