



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H
Heber CA 92249
Tel:(760)482-2440 • Fax (760)353-9951
www.heber.ca.gov

October 6, 2026

Attention: Madeline
General Manager

Subject: September 2026 Monthly Report

On the billing cycles ending on the 20th of September 31,268,000 gallons of water were used by our consumers, an average of 1,008,000 gallons was used per day.

On September 16, 2026 collected third quarter TTHM's samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on September 24, 2026 and were below the maximum contaminant level (MCL) for the both sites. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and for the month of September of 2026 we attained a RAA of 54 ppb for the Mc Cabe Cove site and 49 ppb for the Little Field site. Heber Public Utility District is in compliance with State and Federal water regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel: (760) 482-2440 • Fax (760) 353-9951

October 6, 2026

Attention: Madeline
General Manager

Subject: Water Distribution Report September 2026

A) Water breaks (0)

B) Service Leak (1)

1. 76 10th Street

C) Work orders (74)

INFO - TEST METER	2
MT PR – METER CHANGING PROJECT	38
MC – METER CHANGE	2
MISC – MISC REPORT	4
WTR – SERVICE LINE LEAK	1
HYDRT – HYDRANT LEAK	1
SC – SERVICE CHANGE	1
DIS - DISCONNECT	5
CON - CONNECT	6
OCC - OCCUPANT CHANGE	2
LEAK - METER LEAK	5
TEMP – TEMP SHUT OFF FOR REPAIR	2
ONCAL – ONCALL OPERATOR WAS CA	4
<u>SEWER – SEWER PLUG UP</u>	<u>1</u>

TOTAL ALL CODES	74
-----------------	----

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 · P.O. Box H
Heber, CA 92249
TEL. (760) 482-2440 · FAX (760) 353-9951
www.heber.ca.gov

October 6, 2026,

Attention: Madeline Dessert, General Manager

Subject: Heber Public Utility District Waste Water Treatment Plant Operations from August 20, 2026 through September 20, 2026

- A. Minor Violation: (None)
- B. Major Sewer Spills: (No Spills)
- C. Main Sewer Plugs: (No Sewer Plugs)
- D. UV System: Operational; Self-Cleaning
- E. Vactor Truck: At Shop In Santee
- F. From August 20, 2026 through September 20, 2026 Heber Public Utility District Waste Water Treatment Plant received and treated 12.665 MG
- G. Heber Public Utility District did not exceed the daily maximum flow (1.2 MGD) as of September 20, 2026

Sincerely,

Matthew Hughes
Lead Operator
Heber Public Utility District