



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

January 7, 2025

Attention: Mrs. Dessert  
General Manager

Subject: December 2024 Monthly Report

On the billing cycles ending on the 20th of December 19,145,000 gallons of water were used by our consumers, an average of 638,000 gallons was used per day.

On December 18, 2024, collected the monthly Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on December 27, 2024 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 66 ppb for the Mc Cabe site and 54 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

January 7, 2025

Attention: Madeline  
General Manager

Subject: Water Distribution Report December 2024

A) Water breaks (2)

1. 19 Pheasant Court
2. 1116 Valley Blvd

B) Service Leak (1)

1. 17 Dove Court

C) Work orders ( 61 )

HYDRT - HYDRANT LEAK-----	4
INFO - TEST METER -----	5
MC - METER CHANGE-----	3
CON - CONNECT -----	10
MISC - MISC REPORT -----	6
OCC - OCCUPANT CHANGE-----	4
DIS - DISCONNECT -----	8
LEAK - METER LEAK-----	11
TEMP – TEMP SHUT OFF FOR REPAIR----	2
SWR - SEWER PLUG UP-----	2
WTR – SERVICE LINE LEAK-----	3
PRSUR- TEST WATER PRESSURE-----	2
COMPL – COMPLAINS WATER-----	1

**TOTAL ALL CODES**

**61**

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



## Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H  
Heber, CA 92249  
TEL. (760) 482-2440 • FAX (760) 353-9951  
[www.heber.ca.gov](http://www.heber.ca.gov)

January 7, 2025

Attention: Madeline Dessert  
General Manager

SUBJECT: Heber W.W.T.P. Operations from November 20, 2024 through December 20, 2024.

- A. Major violations: (NONE)
- B. Minor violations: (NONE)
- C. Major sewer spills: (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning. Changed out one broken lamp.
- F. Vactor Truck: Vactor truck was not used this monthly cycle.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0 miles.
- H. From November 20, 2024 through December 20, 2024: Heber Wastewater Plant received and treated 13.666 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of December 20, 2024.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez".

Edoardo S. Gonzalez  
Wastewater Plant Lead Operator





HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report  
 Billing Period : NOVEMBER 20, 2024 thru DECEMBER 20, 2024

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Dec-23	20,976,000	21,708,288	2,543,739	-3,276,027	14,691,000	\$ 135,839.85	\$ 116,781.70	\$ 55,576.30	160 Accounts
Jan-24	20,638,366	18,135,000	1,825,771	677,595	15,560,000	\$ 134,297.40	\$ 117,302.21	\$ 55,426.19	160 Accounts
Feb-24	15,667,000	16,178,248	2,054,462	-2,565,710	17,779,000	\$ 124,392.83	\$ 116,000.69	\$ 55,382.61	160 Accounts
Mar-24	20,322,000	21,108,650	1,837,250	-2,623,900	16,197,000	\$ 129,995.46	\$ 116,490.45	\$ 56,706.82	160 Accounts
Apr-24	25,549,000	24,474,159	2,026,456	-951,615	16,037,000	\$ 137,142.31	\$ 116,538.21	\$ 57,140.44	159 Accounts
May-24	28,843,000	27,127,172	2,558,028	-842,200	14,607,000	\$ 142,812.36	\$ 117,203.17	\$ 57,081.99	159 Accounts
Jun-24	37,690,000	33,120,546	1,813,047	2,756,407	15,141,000	\$ 164,837.06	\$ 117,141.44	\$ 57,132.60	160 Accounts
Jul-24	39,157,000	35,420,583	2,896,894	839,523	14,417,000	\$ 167,879.73	\$ 117,572.65	\$ 59,335.38	160 Accounts
Aug-24	37,804,000	31,835,694	2,348,695	3,619,611	13,568,000	\$ 157,634.05	\$ 117,426.53	\$ 59,321.68	160 Accounts
Sep-24	36,091,000	32,568,946	2,391,872	1,130,182	14,684,000	\$ 158,946.99	\$ 117,782.09	\$ 59,327.03	166 Accounts
Oct-24	30,006,000	28,543,493	2,209,711	-747,204	17,647,000	\$ 146,026.20	\$ 117,155.53	\$ 59,391.78	166 Accounts
Nov-24	24,426,000	24,006,473	1,978,551	-1,559,024	14,475,000	\$ 137,174.61	\$ 116,866.31	\$ 59,398.74	166 Accounts
<b>Dec-24</b>	<b>19,145,000</b>	<b>21,611,874</b>	<b>1,346,649</b>	<b>-3,813,523</b>	<b>13,666,000</b>	<b>\$ 134,472.59</b>	<b>\$ 116,784.19</b>	<b>\$ 59,569.57</b>	<b>166 Accounts</b>

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.

*Liz German*

Liz German  
Office Senior Clerk

1/7/24

Date

## \*\*\*\* TOTALS BY JOB CODE \*\*\*\*

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
DIS - DISCONNECT	8	0	0	0	22
LEAK - METER LEAK	11	0	0	0	0
INFO - TEST METER	5	1	0	0	0
TEMP - TEMP SHUT OF FOR REPAI	2	0	0	0	0
CON - CONNECT	10	0	0	0	0
COMPL - COMPLAINS WATER	1	0	0	0	0
MISC - MISC REPORT	6	0	0	0	0
WTR - SERVICE LINE LEAK	3	0	0	0	0
MC - METER CHANGE	3	0	0	0	1
OCC - OCCUPANT CHANGE	4	0	0	0	0
HYDRT - HYDRANT LEAK	4	0	0	0	0
SWR - SEWER PLUG UP	2	0	0	0	0
PRSUR - TEST WATER PRESSURE	2	0	0	0	0
TOTAL ALL CODES	61	1	0	0	23