



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

February 5, 2026

Attention: Madeline

General Manager

Subject: January 2026 Monthly Report

On the billing cycle ending on the 20th of January 17,318,000 million gallons of water were used by our consumers, an average of 525,000 thousand gallons was used per day.

On January 7, 2026 collected the 1<sup>st</sup> quarter Trihalomethanes (TTHM's) and Haloacetic Acids (Haa5) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on January 20, 2026 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 53 ppb for the Mc Cabe site and 41 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

February 5, 2026

Attention: Madeline  
General Manager

Subject: Water Distribution Report January 2026

- a) Water breaks (0)
- b) Service Leak (2)
  - 1. 35 Long Trail Ct.
  - 2. 1358 Appaloosa Road
- c) Work orders (152)

OCC – OCUPANT CHANGE	4
CON - CONNECT	6
MISC- MISC REPORT	2
DIS - DISCONNECT	4
WTR – SERVICE LINE LEAK	2
LEAK - METER LEAK	8
PRSUR – TEST WATER PRESSURE	1
INFO - TEST METER	4
MC- METER CHANGE	2
SEWER – SEWER PLUG UP	1
ONCALL – ONCALL OPERATOR WAS CALLED	1
MT PR – METER CHANGING PROJECT	114
SC – SERVICE CHANGE	1
CURB – CURP STOP	1
HYDRT – HYDRANT LEAK	1

TOTAL ALL CODES 152

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report  
 Billing Period :DECEMBER 18, 2025 thru JANUARY 20, 2026

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Jan-25	18,836,000	19,157,768	1,531,243	-1,853,011	12,692,000	\$ 132,753.07	\$ 116,527.28	\$ 59,550.93	166 Accounts
Feb-25	19,618,000	20,080,938	1,664,481	-2,127,419	13,489,000	\$ 132,926.63	\$ 116,552.04	\$ 59,527.34	166 Accounts
Mar-25	20,043,000	20,390,552	2,187,885	-2,535,437	12,360,000	\$ 130,169.73	\$ 116,705.53	\$ 59,484.98	166 Accounts
Apr-25	25,993,000	25,137,709	2,961,623	-2,106,332	13,863,000	\$ 135,876.87	\$ 116,928.52	\$ 59,542.32	167 Accounts
May-25	30,161,000	27,730,823	3,556,069	-1,125,892	13,766,000	\$ 140,716.70	\$ 117,062.63	\$ 59,627.47	170 Accounts
Jun-25	33,319,000	30,156,796	3,031,154	131,050	14,599,000	\$ 148,780.49	\$ 117,216.21	\$ 59,639.17	170 Accounts
Jul-25	35,710,000	30,330,332	412,788	4,966,880	14,157,000	\$ 157,505.88	\$ 117,382.10	\$ 61,603.45	173 Accounts
Aug-25	35,291,564	37,781,000	5,036,022	-2,489,436	14,603,000	\$ 159,459.05	\$ 118,187.81	\$ 61,533.43	173 Accounts
Sep-25	31,146,000	29,481,327	4,340,771	1,664,673	14,943,000	\$ 144,984.94	\$ 121,164.92	\$ 61,518.45	173 Accounts
Oct-25	23,984,000	23,340,443	1,371,609	643,557	13,174,000	\$ 136,318.39	\$ 116,871.77	\$ 61,503.80	173 Accounts
Nov-25	22,739,000	21,469,843	1,101,047	1,269,157	13,178,000	\$ 134,331.13	\$ 117,937.44	\$ 61,617.85	173 Accounts
Dec-25	16,748,000	16,854,457	745,323	-106,457	12,762,000	\$ 126,739.03	\$ 122,950.77	\$ 63,452.48	173 Accounts
<b>Jan-26</b>	<b>17,318,000</b>	<b>18,057,257</b>	<b>630,422</b>	<b>-739,257</b>	<b>13,091,000</b>	<b>\$ 129,272.97</b>	<b>\$ 123,312.57</b>	<b>\$ 65,095.68</b>	<b>173 Accounts</b>

Totals includes billing for final accounts  
 To the best of my knowledge, the information is true and correct.

*Liz German*

Liz German  
 Office Senior Clerk

02/10/2026

Date

## \*\*\*\* TOTALS BY JOB CODE \*\*\*\*

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
DIS - DISCONNECT	4	0	0	0	0
CON - CONNECT	6	0	0	0	0
INFO - TEST METER	4	0	0	0	0
SEWER - SEWER PLUG UP	1	0	0	0	0
LEAK - METER LEAK	8	0	0	0	0
ONCAL - ONCALL OPERATOR WAS CA	1	0	0	0	0
WTR - SERVICE LINE LEAK	2	2	0	0	0
MT PR - METER CHANGING PROJECT	114	16	0	0	1
OCC - OCCUPANT CHANGE	4	0	0	0	0
PRSUR - TEST WATER PRESSURE	1	0	0	0	0
MC - METER CHANGE	2	0	0	0	0
SC - SERVICE CHANGE	1	0	0	0	0
CURB - CURB STOP	1	0	0	0	0
HYDRT - HYDRANT LEAK	1	0	0	0	0
MISC - MISC REPORT	2	0	0	0	0
TOTAL ALL CODES	152	18	0	0	1